

■暖房能力表

型番	通水量	通水抵抗	暖房入口空気温度(DB=20℃)			
			温水入口温度(℃)			
			45	50	55	60
I/min	kPa	kW	kW	kW	kW	
40A	39.3	15.4	13.78	16.53	19.29	22.05
	31.2	10.3	13.38	16.07	18.76	21.43
	28.3	18.8	13.93	16.71	19.49	22.29
	24.7	19.6	14.02	16.83	19.63	22.43
	20.8	14.8	13.60	16.34	19.05	21.78
	20.1	17.3	14.29	17.15	20.02	22.91
60	55.6	12.3	19.98	23.97	27.97	31.98
	43.7	8.0	19.35	23.22	27.09	30.98
	41.2	22.3	20.50	24.60	28.71	32.81
	35.4	22.1	20.41	24.51	28.63	32.67
	29.7	16.1	19.79	23.74	27.72	31.66
	30.1	20.5	21.37	25.65	29.93	34.21
80	73.2	25.8	26.29	31.57	36.81	42.08
	56.6	15.5	25.40	30.50	35.58	40.66
	51.7	22.1	26.36	31.63	36.91	42.20
	45.2	22.4	26.57	31.85	37.17	42.49
	37.7	16.0	25.65	30.79	35.93	41.08
	37.4	19.5	27.29	32.76	38.22	43.67
90	85.6	36.6	30.72	36.87	43.02	49.16
	69.5	23.7	29.93	35.91	41.90	47.90
	61.1	31.6	30.44	36.52	42.63	47.02
	53.4	31.8	30.63	36.78	42.95	47.69
	44.1	21.9	29.62	35.52	41.48	44.44
	44.5	27.6	31.84	38.21	44.59	44.51
100A	85.6	39.5	33.37	40.02	46.73	53.44
	75.6	30.4	32.84	39.40	45.99	52.55
	67.0	41.3	33.53	40.26	47.00	53.70
	58.4	41.1	33.71	40.47	47.21	53.94
	48.2	27.8	32.52	39.06	45.56	52.09
	48.2	34.7	34.80	41.77	48.71	55.73

※上記の通水量は冷房時の入口水温TW=7℃、入口空気温度DB=27℃、WB=19℃時の各冷水温度差における水量を示す。

■暖房能力表

型番	暖房入口空気温度(DB=19℃)						暖房入口空気温度(DB=22℃)					
	通水量 (※1)	通水抵抗 (※1)	温水入口温度(℃)				通水量 (※2)	通水抵抗 (※2)	温水入口温度(℃)			
			45	50	55	60			45	50	55	60
I/min	kPa	kW	kW	kW	kW	I/min	kPa	kW	kW	kW	kW	
40A	41.6	17.0	14.42	17.20	19.98	22.76	38.4	14.7	12.64	15.38	18.14	20.90
	32.6	11.1	14.00	16.71	19.40	22.09	30.3	9.8	12.27	14.93	17.60	20.27
	30.0	20.9	14.59	17.41	20.22	23.06	27.4	17.8	12.74	15.52	18.29	21.07
	26.3	21.9	14.72	17.56	20.38	23.22	24.2	19.0	12.85	15.65	18.48	21.24
	22.2	16.5	14.33	17.09	19.85	22.60	20.0	13.8	12.42	15.13	17.83	20.53
	21.6	19.5	15.07	17.97	20.87	23.78	19.3	16.3	13.05	15.88	18.73	21.56
60	58.6	13.6	20.91	24.97	28.95	32.97	54.1	11.8	18.31	22.30	26.29	30.28
	46.2	8.8	20.30	24.20	28.10	32.01	42.5	7.6	17.73	21.58	25.45	29.31
	43.8	25.1	21.53	25.64	29.78	33.92	39.9	21.0	18.77	22.85	26.94	31.02
	37.7	24.9	21.44	25.57	29.71	33.85	34.1	20.7	18.66	22.72	26.80	30.85
	31.7	18.1	20.84	24.85	28.86	32.87	28.5	15.0	18.05	21.99	25.90	29.83
	32.3	23.2	22.51	26.85	31.17	35.52	28.8	18.9	19.49	23.73	27.98	32.22
80	77.2	28.8	27.53	32.81	38.12	43.42	71.5	24.6	24.13	29.36	34.62	39.87
	59.8	17.2	26.62	31.73	36.86	41.98	55.0	14.7	23.27	28.33	33.40	38.48
	54.8	24.8	27.65	32.97	38.28	43.59	50.0	20.7	24.13	29.36	34.62	39.87
	48.1	25.3	27.88	33.29	38.62	43.98	43.6	21.0	24.27	29.53	34.84	40.08
	40.3	18.0	27.05	32.23	37.44	42.65	36.4	14.9	23.43	28.52	33.62	38.71
	40.0	22.1	28.76	34.31	39.84	45.35	35.7	17.9	24.87	30.27	35.73	41.10
90	85.6	36.6	31.94	38.14	44.23	50.41	71.5	24.6	24.13	34.47	40.63	46.81
	73.6	26.7	31.35	37.45	43.44	49.47	67.6	22.4	27.42	33.38	39.34	45.35
	64.7	35.5	31.92	38.06	44.22	50.35	59.2	29.6	27.85	33.91	39.98	46.05
	56.8	36.0	32.17	38.38	44.56	50.77	51.4	29.4	28.00	34.10	40.20	46.28
	47.2	24.9	31.19	37.17	43.19	49.19	42.4	20.3	27.03	32.90	38.83	44.69
	47.8	31.8	33.55	40.01	46.45	52.92	42.6	25.4	29.05	35.37	41.70	48.01
100A	85.6	39.5	34.70	41.36	48.10	57.72	85.6	39.5	30.70	37.42	44.06	50.72
	80.0	34.2	34.42	41.03	47.66	54.29	73.6	28.7	30.16	36.65	43.17	49.72
	71.0	46.7	35.17	41.98	48.73	55.51	65.0	38.7	30.71	37.42	44.09	50.79
	62.3	46.9	35.44	42.26	49.08	55.91	56.3	38.1	30.83	37.52	44.24	50.94
	51.7	32.0	34.36	40.91	47.51	54.14	46.5	26.0	29.72	36.17	42.64	49.13
	51.7	39.9	36.67	43.71	50.78	57.86	46.1	31.8	31.71	38.62	45.52	52.40

※1 暖房入口空気温度DB=19℃の通水量、通水抵抗は冷房時の入口水温TW=7℃、入口空気温度DB=28℃、RH=45%時の各冷水温度差における水量を示す。

※2 暖房入口空気温度DB=22℃の通水量、通水抵抗は冷房時の入口水温TW=7℃、入口空気温度DB=26℃、RH=50%時の各冷水温度差における水量を示す。