

■ 暖房能力表

| 型番 | 通水量 | 通水抵抗 | 暖房入口空気温度(20℃) | | | |
|-------|------|------|---------------|-------|-------|-------|
| | | | 温水入口温度(℃) | | | |
| | | | 45 | 50 | 55 | 60 |
| l/min | kPa | kW | kW | kW | kW | |
| 200 | 5.3 | 6.4 | 2.34 | 2.80 | 3.27 | 3.73 |
| | 4.0 | 3.9 | 2.26 | 2.70 | 3.15 | 3.60 |
| | 3.7 | 31.9 | 2.35 | 2.83 | 3.29 | 3.77 |
| | 3.0 | 21.7 | 2.29 | 2.74 | 3.20 | 3.66 |
| | 3.1 | 28.8 | 2.42 | 2.91 | 3.40 | 3.87 |
| | 2.6 | 21.1 | 2.36 | 2.83 | 3.29 | 3.77 |
| 300 | 8.7 | 18.2 | 3.36 | 4.03 | 4.71 | 5.38 |
| | 6.9 | 11.8 | 3.29 | 3.94 | 4.60 | 5.26 |
| | 6.0 | 12.3 | 3.24 | 3.90 | 4.55 | 5.20 |
| | 4.8 | 8.3 | 3.13 | 3.76 | 4.38 | 5.01 |
| | 4.6 | 69.1 | 3.42 | 4.12 | 4.79 | 5.48 |
| | 3.9 | 50.5 | 3.33 | 4.00 | 4.66 | 5.34 |
| 400 | 10.5 | 9.2 | 4.19 | 5.03 | 5.87 | 6.71 |
| | 8.0 | 5.6 | 4.03 | 4.85 | 5.65 | 6.47 |
| | 7.9 | 23.6 | 4.53 | 5.44 | 6.35 | 7.26 |
| | 6.4 | 16.0 | 4.41 | 5.29 | 6.17 | 7.05 |
| | 6.2 | 18.9 | 4.66 | 5.59 | 6.53 | 7.47 |
| | 5.1 | 13.3 | 4.51 | 5.41 | 6.31 | 7.21 |
| 600 | 15.0 | 22.3 | 5.81 | 6.99 | 8.15 | 9.31 |
| | 11.8 | 14.1 | 5.64 | 6.77 | 7.90 | 9.02 |
| | 10.3 | 48.0 | 6.21 | 7.45 | 8.69 | 9.93 |
| | 8.3 | 31.7 | 5.99 | 7.17 | 8.37 | 9.57 |
| | 8.5 | 41.6 | 6.49 | 7.78 | 9.08 | 10.38 |
| | 7.1 | 29.7 | 6.26 | 7.51 | 8.77 | 10.03 |
| 800 | 19.3 | 20.6 | 8.02 | 9.63 | 11.24 | 12.86 |
| | 15.1 | 12.9 | 7.77 | 9.33 | 10.88 | 12.44 |
| | 14.4 | 36.7 | 8.15 | 9.78 | 11.41 | 13.03 |
| | 11.8 | 25.1 | 7.88 | 9.47 | 11.06 | 12.63 |
| | 11.3 | 95.6 | 8.59 | 10.31 | 12.03 | 13.76 |
| | 9.4 | 66.8 | 8.28 | 9.94 | 11.60 | 13.26 |
| 1200 | 24.0 | 36.4 | 8.90 | 10.66 | 12.43 | 14.21 |
| | 18.5 | 21.9 | 8.56 | 10.29 | 11.99 | 13.71 |
| | 17.5 | 26.4 | 9.40 | 11.27 | 13.14 | 15.03 |
| | 14.4 | 18.3 | 9.07 | 10.90 | 12.71 | 14.52 |
| | 14.8 | 56.0 | 10.12 | 12.14 | 14.16 | 16.20 |
| | 12.4 | 39.9 | 9.78 | 11.73 | 13.69 | 15.65 |

※上記の通水量は冷房時の入口水温7℃、入口空気温度DB=27℃、WB=19℃時の各冷水温度差における水量を示す。

■ 暖房能力表

| 型番 | 通水量 | 通水抵抗 | 暖房入口空気温度(19℃) | | | | 通水量 | 通水抵抗 | 暖房入口空気温度(22℃) | | | |
|-------|------|-------|---------------|-------|-------|-------|------|------|---------------|-------|-------|-------|
| | | | 温水入口温度(℃) | | | | | | 温水入口温度(℃) | | | |
| | | | 45 | 50 | 55 | 60 | | | 45 | 50 | 55 | 60 |
| l/min | kPa | kW | kW | kW | kW | l/min | kPa | kW | kW | kW | kW | |
| 200 | 5.6 | 7.0 | 2.44 | 2.91 | 3.37 | 3.85 | 5.2 | 6.2 | 2.14 | 2.60 | 3.07 | 3.53 |
| | 4.3 | 4.4 | 2.36 | 2.83 | 3.28 | 3.73 | 3.9 | 3.8 | 2.06 | 2.51 | 2.97 | 3.41 |
| | 3.9 | 35.2 | 2.47 | 2.93 | 3.41 | 3.88 | 3.6 | 30.3 | 2.15 | 2.63 | 3.09 | 3.57 |
| | 3.2 | 24.4 | 2.41 | 2.86 | 3.33 | 3.79 | 2.9 | 20.4 | 2.09 | 2.55 | 3.00 | 3.45 |
| | 3.3 | 32.3 | 2.53 | 3.02 | 3.51 | 4.00 | 3.0 | 27.2 | 2.22 | 2.70 | 3.19 | 3.66 |
| | 2.8 | 24.0 | 2.48 | 2.95 | 3.43 | 3.92 | 2.5 | 19.7 | 2.15 | 2.62 | 3.08 | 3.56 |
| 300 | 9.1 | 19.9 | 3.51 | 4.19 | 4.86 | 5.55 | 8.4 | 17.0 | 3.08 | 3.76 | 4.43 | 5.09 |
| | 7.3 | 13.1 | 3.44 | 4.10 | 4.77 | 5.43 | 6.7 | 11.2 | 3.01 | 3.66 | 4.33 | 4.98 |
| | 6.3 | 13.4 | 3.40 | 4.06 | 4.71 | 5.36 | 5.8 | 11.6 | 2.97 | 3.62 | 4.27 | 4.91 |
| | 5.1 | 9.2 | 3.29 | 3.92 | 4.56 | 5.20 | 4.6 | 7.7 | 2.86 | 3.48 | 4.10 | 4.72 |
| | 4.9 | 78.1 | 3.60 | 4.29 | 4.98 | 5.66 | 4.4 | 63.5 | 3.13 | 3.81 | 4.49 | 5.17 |
| | 4.1 | 55.5 | 3.50 | 4.16 | 4.84 | 5.51 | 3.7 | 45.8 | 3.03 | 3.70 | 4.35 | 5.01 |
| 400 | 11.1 | 10.2 | 4.38 | 5.23 | 6.07 | 6.92 | 10.2 | 8.7 | 3.84 | 4.67 | 5.51 | 6.35 |
| | 8.5 | 6.3 | 4.24 | 5.06 | 5.87 | 6.70 | 7.8 | 5.4 | 3.70 | 4.51 | 5.31 | 6.12 |
| | 8.2 | 25.3 | 4.73 | 5.65 | 6.56 | 7.48 | 7.6 | 21.9 | 4.16 | 5.06 | 5.97 | 6.86 |
| | 6.8 | 17.8 | 4.63 | 5.51 | 6.41 | 7.29 | 6.2 | 15.1 | 4.03 | 4.91 | 5.79 | 6.66 |
| | 6.6 | 21.2 | 4.90 | 5.84 | 6.78 | 7.72 | 5.9 | 17.3 | 4.26 | 5.19 | 6.10 | 7.03 |
| | 5.5 | 15.2 | 4.76 | 5.66 | 6.58 | 7.50 | 4.9 | 12.4 | 4.10 | 5.01 | 5.90 | 6.79 |
| 600 | 15.8 | 24.6 | 6.09 | 7.27 | 8.43 | 9.60 | 14.7 | 21.4 | 5.35 | 6.50 | 7.66 | 8.83 |
| | 12.2 | 15.0 | 5.90 | 7.02 | 8.16 | 9.29 | 11.5 | 13.4 | 5.16 | 6.30 | 7.42 | 8.55 |
| | 10.9 | 53.6 | 6.51 | 7.76 | 9.01 | 10.27 | 10.0 | 45.3 | 5.69 | 6.92 | 8.16 | 9.40 |
| | 8.8 | 35.4 | 6.29 | 7.50 | 8.71 | 9.92 | 8.2 | 31.0 | 5.49 | 6.69 | 7.88 | 9.07 |
| | 9.1 | 47.4 | 6.83 | 8.14 | 9.45 | 10.77 | 8.2 | 38.8 | 5.93 | 7.22 | 8.51 | 9.80 |
| | 7.7 | 34.5 | 6.62 | 7.91 | 9.17 | 10.44 | 6.8 | 27.4 | 5.70 | 6.94 | 8.17 | 9.42 |
| 800 | 20.4 | 22.9 | 8.40 | 10.02 | 11.63 | 13.24 | 18.9 | 19.7 | 7.36 | 8.97 | 10.57 | 12.17 |
| | 16.0 | 14.4 | 8.15 | 9.72 | 11.28 | 12.86 | 14.8 | 12.4 | 7.13 | 8.67 | 10.23 | 11.78 |
| | 15.2 | 40.8 | 8.53 | 10.17 | 11.83 | 13.47 | 13.9 | 34.3 | 7.45 | 9.08 | 10.70 | 12.33 |
| | 12.4 | 27.6 | 8.28 | 9.87 | 11.47 | 13.06 | 11.5 | 24.0 | 7.22 | 8.79 | 10.37 | 11.94 |
| | 12.0 | 107.6 | 9.03 | 10.77 | 12.51 | 14.26 | 10.9 | 89.0 | 7.86 | 9.57 | 11.27 | 12.98 |
| | 10.1 | 76.7 | 8.74 | 10.43 | 12.12 | 13.80 | 9.0 | 61.4 | 7.55 | 9.20 | 10.84 | 12.48 |
| 1200 | 25.3 | 40.4 | 9.30 | 11.09 | 12.88 | 14.69 | 23.5 | 34.9 | 8.15 | 9.92 | 11.70 | 13.47 |
| | 19.5 | 24.2 | 8.97 | 10.70 | 12.43 | 14.15 | 18.1 | 21.0 | 7.85 | 9.56 | 11.27 | 12.98 |
| | 18.6 | 29.7 | 9.86 | 11.76 | 13.65 | 15.55 | 17.0 | 25.0 | 8.59 | 10.47 | 12.34 | 14.21 |
| | 15.3 | 20.5 | 9.55 | 11.38 | 13.22 | 15.06 | 13.9 | 17.2 | 8.29 | 10.09 | 11.91 | 13.72 |
| | 15.8 | 63.6 | 10.64 | 12.69 | 14.73 | 16.78 | 14.3 | 52.4 | 9.24 | 11.26 | 13.28 | 15.28 |
| | 13.3 | 45.6 | 10.31 | 12.30 | 14.29 | 16.27 | 12.0 | 37.5 | 8.93 | 10.87 | 12.81 | 14.76 |

※ 暖房入口空気温度19℃の通水量は冷房時の入口水温7℃、入口空気温度DB=28℃、RH=45%時の各冷水温度差における水量を示す。

※ 暖房入口空気温度22℃の通水量は冷房時の入口水温7℃、入口空気温度DB=26℃、RH=50%時の各冷水温度差における水量を示す。