

■ 暖房能力表

型番	通水量	通水抵抗	暖房入口空気温度(20℃)			
			温水入口温度(℃)			
			45	50	55	60
	l/min	kPa	kW	kW	kW	kW
1200	19.4	22.4	7.22	8.67	10.12	11.57
	15.2	14.1	7.00	8.40	9.80	11.20
	14.3	16.9	7.58	9.10	10.62	12.14
	11.5	11.3	7.31	8.77	10.23	11.70
	11.3	31.3	7.81	9.38	10.94	12.51
	9.4	22.3	7.53	9.05	10.56	12.06
1800	25.5	20.7	10.01	12.01	14.01	16.01
	19.7	12.6	9.62	11.55	13.48	15.40
	19.8	17.2	10.73	12.87	15.02	17.16
	15.7	11.2	10.27	12.34	14.38	16.44
	16.0	27.6	11.21	13.43	15.67	17.92
	13.2	19.3	10.74	12.90	15.03	17.19
2400	36.0	30.1	13.67	16.41	19.15	21.90
	27.4	17.6	13.15	15.77	18.41	21.05
	27.3	23.6	14.63	17.52	20.44	23.37
	22.3	16.1	14.10	16.93	19.77	22.58
	21.9	33.2	15.19	18.21	21.26	24.29
	18.4	23.9	14.65	17.58	20.52	23.47
3600	53.8	37.8	20.43	24.53	28.60	32.71
	40.9	21.9	19.62	23.53	27.47	31.40
	40.9	29.5	21.81	26.17	30.55	34.91
	32.9	19.4	21.01	25.22	29.43	33.64
	32.5	35.3	22.59	27.12	31.63	36.16
	27.3	25.3	21.80	26.16	30.52	34.88
4800	70.2	40.1	26.91	32.29	37.67	43.08
	53.3	23.2	25.77	30.93	36.08	41.24
	53.3	31.2	28.71	34.47	40.20	45.95
	42.9	20.5	27.63	33.16	38.69	44.23
	42.2	34.1	29.67	35.60	41.57	47.51
	35.3	24.3	28.62	34.30	40.02	45.73

※上記の通水量は冷房時の入口水温7℃、入口空気温度DB=27℃、WB=19℃時の各冷水温度差における水量を示す。

■ 暖房能力表

型番	通水量	通水抵抗	暖房入口空気温度(19℃)				通水量	通水抵抗	暖房入口空気温度(22℃)			
			温水入口温度(℃)						温水入口温度(℃)			
	45	50	55	60	45	50	55	60				
	l/min	kPa	kW	kW	kW	kW	l/min	kPa	kW	kW	kW	kW
1200	20.4	24.7	7.56	9.00	17.94	11.92	18.9	21.3	6.62	8.06	9.50	10.94
	16.1	15.7	7.34	8.76	10.16	11.57	14.8	13.4	6.42	7.80	9.21	10.60
	15.1	18.7	7.95	9.48	11.00	12.53	13.8	15.8	6.93	8.44	9.95	11.47
	12.3	12.8	7.70	9.17	10.65	12.14	11.2	10.8	6.69	8.14	9.60	11.06
	12.0	35.0	8.21	9.79	11.37	12.95	10.8	28.8	7.13	8.67	10.23	11.78
	10.1	25.4	7.97	9.49	11.02	12.56	9.0	20.6	6.86	8.36	9.85	11.35
1800	27.1	23.3	10.50	12.51	14.53	16.56	25.0	19.9	9.17	11.17	13.17	15.17
	20.5	13.6	10.07	12.01	13.95	15.88	19.3	12.2	8.81	10.73	12.66	14.57
	20.7	18.7	11.23	13.40	15.57	17.72	19.2	16.2	9.81	11.95	14.10	16.23
	16.9	12.8	10.85	12.93	15.02	17.10	15.3	10.7	9.41	11.44	13.50	15.53
	17.0	31.0	11.77	14.03	16.30	18.57	15.4	25.7	10.23	12.44	14.67	16.91
	14.3	22.4	11.38	13.57	15.77	17.97	12.6	17.8	9.77	11.90	14.02	16.15
2400	38.0	33.5	14.31	17.08	19.84	22.59	35.1	28.6	12.53	15.27	18.00	20.73
	29.0	19.7	13.78	16.44	19.10	21.74	26.7	16.8	12.06	14.65	17.28	19.90
	29.0	26.5	15.31	18.27	21.22	24.16	26.4	22.1	13.36	16.26	19.17	22.08
	23.9	18.3	14.85	17.71	20.57	23.44	21.6	15.2	12.90	15.71	18.50	21.31
	23.4	37.7	15.97	19.03	22.12	25.19	21.1	30.9	13.86	16.88	19.90	22.91
	19.8	27.4	15.48	18.49	21.43	24.42	17.6	22.0	13.34	16.24	19.14	22.06
3600	56.8	42.1	21.38	25.52	29.63	33.76	52.6	36.1	18.74	22.83	26.90	30.98
	43.4	24.6	20.59	24.55	28.51	32.48	40.0	21.0	17.97	21.88	25.80	29.71
	43.4	33.2	22.90	27.29	31.71	36.10	39.5	27.6	19.95	24.30	28.64	32.98
	35.2	22.1	22.10	26.36	30.64	34.88	32.3	18.8	19.26	23.44	27.63	31.83
	34.8	40.3	23.79	28.36	32.92	37.52	31.2	32.6	20.62	25.12	29.60	34.08
	29.1	28.6	22.99	27.43	31.84	36.27	26.1	23.3	19.85	24.16	28.48	32.80
4800	71.3	41.4	28.05	33.43	38.85	44.23	68.7	38.4	24.67	30.05	35.43	40.78
	56.4	25.9	27.06	32.26	37.49	42.70	52.1	22.2	23.62	28.76	33.90	39.05
	56.8	35.4	30.22	35.98	41.79	47.59	51.8	29.5	26.30	32.00	37.72	43.47
	45.9	23.4	29.09	34.71	40.30	45.91	41.5	19.3	25.23	30.73	36.24	41.74
	45.3	39.1	31.28	37.31	43.33	49.34	40.6	31.6	27.08	32.99	38.90	44.80
	37.7	27.5	30.22	35.99	41.79	47.59	33.8	22.4	26.03	31.69	37.34	43.00

※暖房入口空気温度19℃の通水量は冷房時の入口水温7℃、入口空気温度DB=28℃、RH=45%時の各冷水温度差における水量を示す。

※暖房入口空気温度22℃の通水量は冷房時の入口水温7℃、入口空気温度DB=26℃、RH=50%時の各冷水温度差における水量を示す。